

---

**Sparrow's nest**

1 message

---

**Ryan Roberts** <ryroberts@cottlevillefpd.org>  
To: angela@angelalockett.com

Wed, Nov 16, 2022 at 9:25 AM

Angela,

Based on our conversation, I understand that you are amending your application to the State, reducing the number of children at your proposed daycare. Since you are setting the upper limit of children to five, I believe that Section 308.6.4 of the 2015 edition of the International Building Code is pertinent. It states "A facility such as above within a dwelling unit and having five or fewer persons receiving custodial care shall be classified as a Group R-3 occupancy or shall comply with the International Residential Code."

The Cottleville Fire District does not enforce regulations relating to R-3 occupancies. R-3 occupancies are single- and two-family residences. Therefore, there are no further upgrades needed to the fire department access or water supply required by our fire district.

I hope this answers your questions. Please let me know if you have any other questions, or I can be of further assistance.

Respectfully,

Ryan Roberts  
Assistant Chief/Fire Marshal  
Cottleville Fire Protection District  
O- (636) 447-6655, extension 8702  
C- (636) 577-8259  
[ryroberts@cottlevillefpd.org](mailto:ryroberts@cottlevillefpd.org)

