

March 7, 2013

ADDENDUM #1

13-073 Broemmelsiek Park Off Leash Chain Link Fence Expansion

Addendum 1 is being issued to clarify chain link fence specification as to gauge.

1. Under the General Specification for:

1000' Chain Link Fence

Original spec called for 8 gauge heavy duty

Specification should be as below;

“9-gauge core, 8-gauge finish, fuse bonded pvc coated chain link fence”

Bidders shall sign this Addendum as acknowledgment and return it with the bid.

BID ADDENDUM

Addendum #1

Dated_____

We, the undersigned, acknowledge the receipt of the above addendum(s) as dated.

By:_____

Title:_____

Company:_____

Date: _____