

April 17, 2013

ADDENDUM #2

13-084 Purchase & Installation of Burglar & Fire Alarm System

This Addendum is being issued as a response to questions received regarding the bid package.

Questions received from Reinhold Electric

1. Is the Bosch Cut Sheet-GV4 Series Fire alarm panel acceptable?

Answer:

Please submit any alternate materials/supplies as a separate bid item with written justification as to why it should be regarded as an approved equal.

2. Regarding Note 11, page 9 of the Bid Specs – Are you wanting us to have the Fire Alarm U.L. certified after it's installed? Or just a copy of our Monitoring/Service company U. L. certification?

Answer:

All materials and supplies must be U.L. listed. A copy of the monitoring/service company U . L. certification will suffice. All local fire codes must be adhered to.